

Applicant : EAE Elektrotechnik San. Ve Tic. A.S.
Ikitelli Organize Sanayi
Bölgesi Turgut Özal
Caddesi No 112
34306 Ikitelli - Istanbul
Turkey

Application date : April 19, 2010

Order number : 213488300

Subject : Degree of protection provided by LV and MV compartments of
MV metal enclosed metal segregated modular switchboard, IP4X

Trademark : EAE

Type : M36 Series


Arnhem, April 20, 2010


Manufacturer/ Production site: EAE Elektrotechnik San. Ve Tic. A.S.
Ikitelli Organize Sanayi
Bölgesi Turgut Özal
Caddesi No 112
34306 Ikitelli – Istanbul, Turkey

Overview of tests : See page 2

Test requirements : EN/IEC 60529:1989 + A1:1999

Conclusion : The tested enclosure complies with the specified requirements

Tested by : R. Verhagen 

Checked by : H.L. Schendstok 

Contents

- Test description and test results
- 4 Photographs
- 1 Drawing

RVer 0149-10

© KEMA Quality B.V., Arnhem, The Netherlands. All rights reserved.

It is prohibited to change any and all versions of this document in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version (e.g. PDF file) and the original paper version provided by KEMA Quality, the latter will prevail.

KEMA Quality B.V. and/or its associated companies disclaim liability for any direct, indirect, consequential or incidental damages that may result from the use of the information or data, or from the inability to use the information or data contained in this document.

The contents of this report may only be transmitted to third parties in its entirety and provided with the copyright notice, prohibition to change, electronic versions' validity notice and disclaimer.

Products may only be provided with a quality mark or put on the market as approved if KEMA Quality B.V. has explicitly granted the right to carry a quality mark.